

CERTIFICATE

ELECTROMAGNETIC COMPATIBILITY

Applicant : **Datakom Elektronik Mühendislik Ltd. Şti.**
Contact person : **Metin Hekimoğlu**
Address : **Şerifali Mahallesi Bayraktar Bulvarı Kutup Sokak No:26 Ümraniye**
Postal code, Place : **34775 İstanbul**
Country : **Turkey**

Electrical apparatus : **Automatic mains failure unit**
Trademark : **Datakom**
Type designation : **DKG 509, DKG 519**

Environment : **Industrial**

EN 61326-1:2006 Equipment for measurement, control and laboratory use

EN 55011:2007 RF Emission
+A2:2007

EN 61000-4-2:2001 Electrostatic discharge (ESD) immunity
EN 61000-4-3:2006 Radiated Electro-Magnetic field immunity
+A1:2008

EN 61000-4-4:2004 Electrical Fast Transient (EFT) immunity
EN 61000-4-5:2006 SURGE transient immunity
EN 61000-4-6:2009 Immunity to RF conducted disturbances
EN 61000-4-8:2010 Power frequency immunity

The undersigned declares that the described products meet the essential requirements of the **EMC Directive 2004/108/EC**, based on a non-recurrent examination. The results are recorded in our test report with reference 2145634.0501-EMC.

DEKRA Certification B.V.
(Notified Body EMC)
Arnhem, 30 May, 2011



ing A.T. van der Meijden
Certification Manager EMC

Certificate nr. **2145634.0551-EMC**

Integral publication of this certificate and associated reports may be used in its original form only.

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

DEKRA Certification B.V. Utrechtseweg 310, 6812 AR Arnhem PO Box 5185, 6802 ED Arnhem, The Netherlands
T +31 26 356 2000 F +31 26 352 5800 www.dekra-certification.com Chamber of Commerce nr. 09085396